

# GENERAL CONTRACTORS

*Please acknowledge receipt of Addendum No. 1 via email to  
[office@nciengineering.com](mailto:office@nciengineering.com)*

## South Wind Water and Sewer District Phase 2 Improvements

**Addendum No. 2  
NCI Engineering  
(406) 453-5478**

**March 30, 2018**

To Planholders,

Provisions of this addendum shall become part of the Contract Documents for the above referenced project. **Length of contract time and place of bid remains as specified. The date of bid has been changed to Tuesday April 10 2018 at 3:00 PM.**

This addendum consists of this document of 2 pages numbered Page AD2-1 through Page AD2-2.

General Items of Clarification are:

- 1. The owner will accept bids for either or both approved WWTP vendors. Bidders are not required, but encouraged to bid both approved systems.**
- 2. We anticipate the raw water lift station controls will be the master controller for the WWTP and will consider an integrated control system for the lift station and WWTP. We anticipate dosing on a timed basis with independent controls.**

The Contract Documents are hereby amended as follows:

### **Contract Documents and Specifications**

#### **1. Section 00100 Invitation to Bid**

Revise the first paragraph to read "Separate sealed bids.....will be received at the offices of NCI Engineering Co. at 4509 North Star Boulevard, Great Falls, Montana **until 3:00 p.m. local time on Tuesday April 9 2018,** and then publicly opened and read aloud." This language supercedes that of Addendum #1.

## **2. Section 00300 Bid Form**

Bid form was revised in Addendum #1. Bidders are not required to bid both prequalified Waste Water Treatment Plants (bid items 201A and 201B) but are encouraged to do so. A bid received with either item 201A or 201B blank will be considered a responsive and responsible bid. Measurement and payment (Section 17000) item 201 holds for both bid item 201A and 201B.

## **3. Section 15000 WWTP Proposal Requirements, Article 3.5 paragraph 3: Change to read:**

During the initial operation phase, Vendor shall attend to the system as required for satisfactory operation and shall provide up to three (3) initial 8 hour days of on-site hours of training to the Owner's operator. The initial operation phase shall continue until the Engineer orders acceptance testing as defined in the Technical Specifications.

## **4. Section 15180, Dosing Pumps:**

**a. Article 1.5 Warranty: paragraph 3:** Change both warranties to 7 years.

**b. Article 2.1.A. General:** Change first sentence to read three (3) submersible wet pit sewage pumps. Note that the engineer looked at a more efficient effluent pump with a tighter impeller but could not find an acceptable pump that met head and flow conditions.

## **5. Section 17000 Measure and Pay Article 201. Change bid item 201 to 201A and 201B.**