

GENERAL CONTRACTORS

*Please acknowledge receipt of Addendum via email to
office@nciengineering.com*

South Wind Water and Sewer District Phase 2 Improvements

**Addendum No. 3
NCI Engineering
(406) 453-5478**

April 4, 2018

To Planholders,

Provisions of this addendum shall become part of the Contract Documents for the above referenced project. **Length of contract time and place of bid remains as specified. The date of bid has been changed to Tuesday April 10 2018 at 3:00 PM.**

This addendum consists of this document of 1 page numbered Page AD3-1

The Contract Documents are hereby amended as follows:

Contract Documents and Specifications

1. Section 00100 Invitation to Bid

Revise the first paragraph to read "Separate sealed bids.....will be received at the offices of NCI Engineering Co. at 4509 North Star Boulevard, Great Falls, Montana **until 3:00 p.m. local time on Tuesday April 10 2018**, and then publicly opened and read aloud." This language supersedes that of Addendum #1.

2. Section 15010 Article 2.1.C - WWTP Performance and design requirements.

- a. Add sentence: Wastewater characteristics listed are estimated monthly averages. Peak characteristics may be 25% higher, depending on time of day and day of week.
- b. Item 6. TSS: 216 is a typographical error. This number should be 266.

Phase 2 South Wind Water and Sewer Improvements

Phase 2 South Wind Water and Sewer Improvements

Addendum 3
PageAD3 – 2