

# GENERAL CONTRACTORS

*Please acknowledge receipt of Addendum via email to  
[office@nciengineering.com](mailto:office@nciengineering.com)*

## South Wind Water and Sewer District Phase 2 Improvements

**Addendum No. 4  
NCI Engineering  
(406) 453-5478**

**April 6, 2018**

To Planholders,

Provisions of this addendum shall become part of the Contract Documents for the above referenced project. This addendum consists of this document of 1 page numbered Page AD4-1

**For bonding and insurance purposes, the address of the site is 5455 Lower River Road, GTF Mt. 59405**

The Contract Documents are hereby amended as follows:

### **Contract Documents and Specifications**

**Section 17000, bid item 406:** For clarification, this bid item is for contractor coordination effort with Northwestern Energy. The owner will contract directly with NWE for service installation.

### **Plan Sheets**

**FM-1 through FM-3:** Compact 3" FM in trench to 85% of ASTM D 698 max dry density to station 7+60. Wheel roll 3" FM from station 7+60 into drain field zones. Bed with select native material per spec.

**Sheet DF-1:** Note on left hand side: Delete reference to treatment plant control building.

**Sheet FM-1: Note on left hand side:** Valve vault for plug and check valves shall be 60 inch diameter RCP flat top manhole. I E elev. = 32.0, rim elev.= 39.0. Install manhole steps and conventional eccentrically placed casting.

Phase 2 South Wind Water and Sewer Improvements